



Global-Mark Pty Ltd,  
Suite 4.07, 32 Delhi Road,  
North Ryde NSW 2113,  
Australia

Tel: +61 (0)2 9886 0222 –

[www.Global-Mark.com.au](http://www.Global-Mark.com.au)

**Certificate Holder:**

NRG Building Systems  
(Aust) Pty Ltd  
3/13-15 Octal St Yatala,  
QLD 4207

Tel: +61 (0)2 6672 2227 -

[www.nrggreenboard.com](http://www.nrggreenboard.com)

# Certificate of Conformity

Certificate number: CM30005 Rev3

THIS IS TO CERTIFY THAT

## NRG Greenboard™ Insulated Wall Cladding System

**Type and/or use of product:**

NRG Greenboard™ Insulated Wall Cladding System is an External Wall Cladding System with thermal insulation properties.

**Description of product:**

- Expanded polystyrene: 40, 50, 60, 75 or 100mm thick complying with Class M of AS 1366.3–1992 (R 2018), which contains Bifenthrin
- Direct fixed to stud framing by screws and PVC washers or fixed to stud framing through EPS battens to form a drainage cavity
- PVC (UV stabilized) or Aluminium beading
- 5 x 5 mm alkali resistant fibreglass mesh reinforcement
- Polymer modified render system to NRG Render Specification
- Acrylic based texture membrane coating

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S)

BCA 2022

	Volume One		Volume Two including ABCB Housing Provisions	
<b>Performance Requirement(s)</b>	B1P1 (1) & (2) (a),(b),(c),(d),(h),(j),(k) & (l)	Structural reliability	H1P1 (1) & (2) (a),(b),(c),(d),(h),(j),(k) & (l) & (3)	Structural stability and resistance
	B1P2	Structural resistance		
	F1P4	Rising damp	H2P2	Weatherproofing

**Scope of certification:** The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website [www.abcb.gov.au](http://www.abcb.gov.au). This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the certificate holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

**Disclaimer:** The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.

The purpose of Global-Mark **construction site audits** is to confirm the practicability of installing the product; and to confirm the appropriateness and accuracy of installation instructions. In placing the **CodeMark mark** on the product/system, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the **expertise of external bodies** (laboratories, and technical experts).

Herve Michoux  
Global-Mark Managing Director

Peter Gardner  
Unrestricted Building Certifier

Date of issue: 24/11/2023

Date of expiry: 17/05/2025



# Certificate of Conformity

	F3P1	Weatherproofing	H2P3	Rising damp
<b>Deemed-to-Satisfy Provision(s):</b>	Specification 3	Fire Hazard Properties		
	G5D3	Construction in Bushfire Prone Areas – Protection To BAL-29	H7D4	Construction in bushfire prone areas To BAL-29
	J4D3	Thermal construction – general	13.2.2	Building fabric thermal insulation
	J4D6	Walls and glazing	13.2.5	Energy efficiency– External Walls
<b>State or territory variation(s):</b>	SA F1P4	Rising damp	NSW H2P3	Rising damp
	NSW G5D3	Construction in Bushfire Prone Areas – Protection	SA H2P3	Rising damp
	TAS Section J (NCC2019 A1 Section J)	Compliance with BCA provisions	NSW H7D4	Bushfire Areas – Acceptable construction manual
	NSW J4D3	Thermal construction – general	NSW 13.2.5	Energy efficiency– External Walls
	NSW J4D6	Energy Efficiency – Walls and glazing	NT 13.2.5	Energy efficiency– External Walls
	NSW Section J (NSW NCC2019 A1 NSW J(A)1.2)	Compliance with BCA provisions	TAS Part 13.2 (NCC2019 A1 P2.6.1)	Energy efficiency
			NSW part H6 (NSW NCC2019 A1 3.12.1.4)	Building fabric - external walls
<b>SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B</b>				
<b>Limitations and conditions:</b>				<b>Building classification/s</b>
<p>1. General</p> <p>Compliance with the above BCA Provisions is subject to design and construction being carried out in accordance with the NRG Greenboard™ Specification 11th Edition (Aug 2022) and the following requirements:</p> <ol style="list-style-type: none"> <li>a. Wall thermal insulation performance shall be determined using the insulation values for NRG Greenboard™ specified in Table 1.</li> <li>b. Fastener spacings shall not exceed the specified maximum spacing for the site wind class as per Table 2, Table 3, Table 4, Table 5.</li> <li>c. Damp-proof courses complying with AS/NZS 2904:1995 (incorporating Amendment No.1 and Amendment No.2) shall be provided and the product installed above the finished ground or paving level.</li> </ol>				Class 1, 2, 3, 4, 5, 6, 7, 8, 9 and 10

# Certificate of Conformity

<p>d. In bushfire areas, construction shall also be carried out in accordance with the relevant requirements of AS 3959-2018 (incorporating Amendment No.1 and Amendment No.2) for bushfire attack levels up to BAL-29.</p> <p>e. Where NRG Greenboard™ is installed, electrical installations must comply with AS/NZS 3000:2018.</p>	
<p>2. General Excludes compliance with NCC 2022 Volume One Section C: compliance for non-combustibility, fire hazard properties when used as a wall lining, fire hazard properties when used as a composite member (e.g. insulation within a wall), fire hazard properties generally, and regarding fire resistance or fire resistance levels.</p>	Class 1, 2, 3, 4, 5, 6, 7, 8, 9 and 10
<p>3. General Excludes compliance NCC 2022 Volume Two Part H3: compliance for non-combustibility and regarding fire resistance or fire resistance levels (FRL).</p>	Class 1, 2, 3, 4, 5, 6, 7, 8, 9 and 10
<p>4. Volume 1 – G5D3 In designated bushfire prone areas subject to Bushfire Attack up to and including BAL 29, when the building is constructed in accordance with AS3959: 2018 including Amendment 1 &amp; 2 for the bushfire level attack level considered, NRG Greenboard™ with a 75mm minimum thickness is permitted for use in a wall constructed in accordance with the Exova Warringtonfire Summary of assessment 26733 SOA6.1</p>	Class 2, 3 and 10a or deck immediately adjacent or connected to building Class 2 or 3
<p>5. Volume 2 (+ Housing Provisions) – H7D4 In designated bushfire prone areas subject to Bushfire Attack up to and including BAL 29, when the building is constructed in accordance with either:</p> <ul style="list-style-type: none"> <li>- AS3959: 2018 including Amendment 1 &amp; 2</li> <li>- NASH Standard – Steel Framed Construction in Bushfire Areas</li> </ul> <p>for the bushfire level attack level considered, NRG Greenboard™ with a 75mm minimum thickness is permitted for use in a wall constructed in accordance with the Exova Warringtonfire Summary of assessment 26733 SOA6.1</p>	Class 1 and 10a or deck immediately adjacent or connected to building class 1
<p>6. Volume 1 – NSW G5D3 In designated bushfire prone areas subject to all Bushfire Attack Level BAL-Low, BAL-12.5, BAL-19 and BAL-29, determined in accordance with the Planning for Bush Fire Protection 2019 including addendum November 2022, when the building is constructed in accordance with AS3959: 2018 including Amendments 1 &amp; 2 except as modified by Planning for Bush Fire Protection 2019 including addendum November 2022, NRG Greenboard™ with a 75mm minimum thickness is permitted for use in a wall constructed in accordance with the Exova Warringtonfire Summary of assessment 26733 SOA6.1</p> <p>The compliance assessment of the certified system is limited to sections 7.5 and 8.3.2 of the Planning for Bush Fire Protection 2019 including addendum November 2022.</p> <p>Site specific conditions arising from:</p> <ul style="list-style-type: none"> <li>• the development consent following consultation with the NSW Rural Fire Service under section 4.14 of the Environmental Planning and Assessment Act 1979 if required, or</li> </ul>	Class 2, Class 3, Class 4 part of a building & Class 10a building or deck immediately adjacent or connected to building Class 2, Class 3 or Class 4 part of a building

# Certificate of Conformity

<ul style="list-style-type: none"> <li>the development consent with a bushfire safety authority issued under section 100B of the Rural Fires Act 1997 for the purposes of integrated development have not been considered for the compliance assessment.</li> </ul>	
<p>7. Volume 2 (+ Housing Provisions) – NSW H7D4</p> <p>In designated bushfire prone areas subject to all Bushfire Attack Level BAL-Low, BAL-12.5, BAL-19 and BAL-29, determined in accordance with the Planning for Bush Fire Protection 2019 including addendum November 2022, when the building is constructed in accordance with either</p> <ul style="list-style-type: none"> <li>AS3959: 2018 including Amendments 1 &amp; 2 except as modified by Planning for Bush Fire Protection 2019 including addendum November 2022,</li> <li>NASH Standard – Steel Framed Construction in Bushfire Areas except as modified by Planning for Bush Fire Protection 2019 including addendum November 2022,</li> </ul> <p>NRG Greenboard™ with a 75mm minimum thickness is permitted for use in a wall constructed in accordance with the Exova Warringtonfire Summary of assessment 26733 SOA6.1.</p> <p>The compliance assessment of the certified system is limited to sections 7.5 and 8.3.2 of the Planning for Bush Fire Protection 2019 including addendum November 2022.</p> <p>Site specific conditions arising from:</p> <ul style="list-style-type: none"> <li>the development consent following consultation with the NSW Rural Fire Service under section 4.14 of the Environmental Planning and Assessment Act 1979 if required, or</li> <li>the development consent with a bushfire safety authority issued under section 100B of the Rural Fires Act 1997 for the purposes of integrated development</li> </ul> <p>have not been considered for the compliance assessment.</p>	<p>Class 1 &amp; 10a building or deck associated with a building Class 1</p>
<p>8. Volume 1 – J4D3, J4D6, NSW J4D3, NSW J4D6 and Volume 2 (+ Housing Provisions) – 13.2.2, 13.2.5, NSW 13.2.5, NT 13.2.5</p> <p>NRG Greenboard™ contributes to the thermal resistance of the building fabric, thereby contributing to the requirements of NCC Volume One J4D3, J4D6, NSW J4D3, NSW J4D6 and ABCB Housing Provisions 13.2.2, 13.2.5, NSW 13.2.5, NT 13.2.5 as detailed in section A6 of this certificate.</p> <p>In NSW, Applicable to class 1, 2, 4 and 10 where the development consent requires a BASIX Single Dwelling or Multi Dwelling Certificate 4.0 or later.</p>	<p>Class 1, 2, 3, 4, 5, 6, 7, 8, 9 and 10</p>
<p>9. Volume 1 – NSW Section J (NSW NCC2019 A1 NSW J(A)1.2), TAS Section J (NCC2019 A1 Section J) and Volume 2 (+ Housing Provisions) – NSW Part H6 (NSW NCC2019 A1 3.12.1.4), TAS Part 13.2 (NCC2019 A1 P2.6.1)</p> <p>NRG Greenboard™ contributes to the thermal resistance of the building fabric, thereby contributing to the requirements of Volume One NSW Section J (NCC2019 NSW J(A)1.2 and Volume Two NSW Part H6 (NCC2019 +A1 3.12.1.4) as detailed in section A6 of this certificate.</p>	<p>Class 1, 2, 4 and 10</p>



# Certificate of Conformity

In NSW, Applicable to class 1, 2, 4 and 10 where the development consent requires either:

- a BASIX Single Dwelling or Multi Dwelling Certificate 3.0 or earlier or
- a BASIX Alteration and additions Certificated.



# Certificate of Conformity

## APPENDIX A – PRODUCT TECHNICAL DATA

### A1 Type and intended use of product

See “Type and/or use of product “on page 1.

### A2 Description of product

See “Description of product:” on page 1

The cladding system is fixed to a stud frame, incorporating a reflective or non-reflective cavity and plasterboard lining.

### A3 Product specification

Refer to NRG Greenboard™ Specification 11th Edition (Aug 2022).

### A4 Manufacturer and manufacturing plant(s)

3/13-15 Octal St Yatala, QLD 4207

8/31 Lundberg Drive, Murwillumbah, NSW 2484

### A5 Installation requirements

Product installation shall be carried out in accordance with the NRG Greenboard™ Specification 11th Edition (Aug 2022) by an NRG trained and competent person (having received the NRG Greenboard™ Certificate of Competence) under the direction of a Builder.

An Application for NRG CodeMark Certification Form shall be completed and signed by the Supplier, Builder and Installer. This form must be signed by the Builder, and submitted to NRG, with the copy issued to the owner.

Fixing of NRG Greenboard™ to framing shall be in accordance with Tables 2 to 5.

### A6 Other relevant technical data

Any referenced documents within the technical literature identified in Appendix A, A3 and Appendix A, A5.

In accordance with NCC Volume One Specification 3, NRG Greenboard achieves the following fire hazard properties (as a polystyrene insulation material only), tested in accordance with AS/NZS 1530.3:1999:

Ignitability Index -	6
Spread of Flame Index -	0
Heat Evolved Index -	1
Smoke Developed Index -	4

# Certificate of Conformity

Thermal insulation for use in walls (assessed based on ASTM C518, referenced in AS/NZS 4859.1:2018).

The thermal resistances in Table 1 are of the NRG Greenboard™ insulation alone (i.e. corresponding to “added insulation” as used in the NCC). The total thermal resistance of a wall system is the sum of values for the external air film (0.04), external cladding, air space or cavity (if applicable), NRG Greenboard™ insulation (from Table 1), internal cladding, and internal air space (0.12).

The calculated thermal resistance values do not account for thermal bridging at studs and the like.

NRG Greenboard Thickness (mm)	Thermal Resistance (m <sup>2</sup> .K/W)	Equivalent R rating
40	1.03	1.03
50	1.28	1.28
60	1.54	1.54
75	1.93	1.93
100	2.57	2.57

**Table 2: NRG Greenboard™ Cladding Fixing Requirements – General Areas**

40mm NRG Greenboard™ Cladding			50-60mm NRG Greenboard™ Cladding			75-100mm NRG Greenboard™ Cladding		
Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)	Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)	Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)
N1	450	300	N1	450	300	N1	450	300
N2	450	300	N2	450	300	N2	450	300
N3	450	300	N3	450	300	N3	450	300
N4	450	300	N4	450	300	N4	450	300
N5	450	200	N5	450	200	N5	450	275
C1	450	300	C1	450	300	C1	450	300
C2	450	200	C2	450	200	C2	450	250
C3	450	130	C3	450	130	C3	450	175
C4	450	90	C4	450	90	C4	450	115

**Table 3: NRG Greenboard™ Cladding Fixing Requirements – General Areas**

40mm NRG Greenboard™ Cladding			50-60mm NRG Greenboard™ Cladding			75-100mm NRG Greenboard™ Cladding		
Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)	Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)	Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)
N1	600	300	N1	600	300	N1	600	300
N2	600	300	N2	600	300	N2	600	300
N3	600	250	N3	600	250	N3	600	250
N4	600	225	N4	600	225	N4	600	225
N5	600	150	N5	600	150	N5	600	200
C1	600	250	C1	600	250	C1	600	250
C2	600	150	C2	600	150	C2	600	250
C3	600	95	C3	600	95	C3	600	130
C4	600	65	C4	600	65	C4	600	85



# Certificate of Conformity

**Table 4: NRG Greenboard™ Cladding Fixing Requirements – Within 1,200 mm of Edges**

40mm NRG Greenboard™ Cladding			50-60mm NRG Greenboard™ Cladding			75-100mm NRG Greenboard™ Cladding		
Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)	Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)	Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)
N1	450	300	N1	450	300	N1	450	300
N2	450	300	N2	450	300	N2	450	300
N3	450	250	N3	450	250	N3	450	300
N4	450	225	N4	450	225	N4	450	230
N5	450	150	N5	450	150	N5	450	160
C1	450	250	C1	450	250	C1	450	240
C2	450	150	C2	450	150	C2	450	160
C3	450	95	C3	450	95	C3	450	100
C4	450	65	C4	450	65	C4	450	70

**Table 5: NRG Greenboard™ Cladding Fixing Requirements – Within 1,200 mm of Edges**

40mm NRG Greenboard™ Cladding			50-60mm NRG Greenboard™ Cladding			75-100mm NRG Greenboard™ Cladding		
Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)	Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)	Wind Classification	Stud Spacing (mm)	Fastener Spacing Vertically (mm)
N1	600	250	N1	600	250	N1	600	250
N2	600	225	N2	600	225	N2	600	225
N3	600	210	N3	600	210	N3	600	210
N4	600	140	N4	600	140	N4	600	170
N5	600	90	N5	600	90	N5	600	120
C1	600	140	C1	600	140	C1	600	160
C2	600	90	C2	600	90	C2	600	120
C3	600	60	C3	600	60	C3	600	75
C4	600	45	C4	600	45	C4	600	50

## APPENDIX B – EVALUATION STATEMENTS

### B1 Evaluation methods

The following assessment methods have been used to determine compliance with NCC 2022:

Code Clause	Assessment Method(s)	Evidence of suitability	Evidence reference in B2
<b>Volume One</b>			
B1P1 (1) & (2) (a),(b),(c),(d),(h),(j),(k) & (l)	Volume One A2G2(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 3
		Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person	Items 8, 9, 10, 11, 12 and 13
B1P2	Volume One A2G2(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Items 3 and 8
		Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person	Items 9, 10, 11, 12 and 13
F1P4	Volume One A2G2(2)(d)	Comparison with the Deemed-to-Satisfy Provisions in Volume One F1D6 and F1D7	Item 14
	Volume One A2G2(2)(a)	Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person	Items 9 and 11
F3P1	Volume One A2G2(2)(a)	Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person	Items 9 and 11
Specification 3	Volume One A2G3(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Items 1, 2, 5, 6, and 7
G5D3	Volume One A2G3(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Items 1, 2, 5, 6, and 7
J4D3	Volume One A2G3(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
J4D6	Volume One A2G3(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
SA F1P4	Volume One A2G2(2)(d)	Comparison with the Deemed-to-Satisfy Provisions in Volume One F1D6 and F1D7	Item 14
	Volume One A2G2(2)(a)	Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person	Items 9 and 11
NSW G5D3	Volume One A2G3(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Items 1, 2, 5, 6, and 7
TAS Section J (NCC2019 A1 Section J)	Volume One A2G3(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
NSW J4D3	Volume One A2G3(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
NSW J4D6	Volume One A2G3(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
NSW Section J (NSW NCC2019 A1 NSW J(A)1.2)	Volume One A2G3(2)(a)	Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
<b>Volume Two</b>			
Volume Two H1P1 (1) & (2) (a),(b),(c),(d),(h),(j),(k) & (l) & (3)	Volume Two A2G2(2)(a)	Volume Two A5.2(1)(e) A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person	Items 8, 9, 10, 11, 12 and 13

Code Clause	Assessment Method(s)	Evidence of suitability	Evidence reference in B2
		Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 3
Volume Two H2P2	Volume Two A2G2(2)(a)	Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person	Items 9 and 11
	Volume Two A2G2(2)(d)	Comparison with the Deemed-to-Satisfy Provisions in Housing provisions Part 7.5	Item 14
Volume Two H2P3	Volume Two A2G2(2)(a)	Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person	Items 9 and 11
	Volume Two A2G2(2)(d)	Comparison with the Deemed-to-Satisfy Provisions in Housing provisions Part 6	Item 14
Volume Two H7D4	Volume Two A2G3(2)(a)	Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Items 1, 2, 5, 6, and 7
Volume Two 13.2.2	Volume Two A2G3(2)(a)	Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
Volume Two 13.2.5	Volume Two A2G3(2)(a)	Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
NSW H2P3	Volume Two A2G2(2)(d)	Comparison with the Deemed-to-Satisfy Provisions in Housing provisions Part 6	Item 14
SA H2P3	Volume Two A2G2(2)(a)	Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person	Items 9 and 11
	Volume Two A2G2(2)(d)	Comparison with the Deemed-to-Satisfy Provisions in Housing provisions Part 6	Item 14
NSW H7D4	Volume Two A2G3(2)(a)	Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Items 1, 2, 5, 6, and 7
NSW 13.2.5	Volume Two A2G3(2)(a)	Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
NT 13.2.5	Volume Two A2G3(2)(a)	Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
TAS Part 13.2 (NCC2019 A1 P2.6.1)	Volume Two A2G3(2)(a)	Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4
NSW Part H6 (NSW NCC2019 A1 3.12.1.4)Volume Two 3.12.1.4	Volume Two A2G3(2)(a)	Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory	Item 4

## B2 Reports

The following reports have been used as evidence to determine compliance with NCC 2022:

Ref	Author	Reference	Date	Description	NATA Registration
1	Australian Wool Testing Authority (AWTA) Product Testing	Test Report Number: 7-566170-CQ	4/5/2009	AS/NZS 1530.3:1999, "Simultaneous determination of Ignitability, Flame Propagation, Heat Release and Smoke Release"	Accreditation No. 1356
2	Australian Wool Testing Authority (AWTA) Product Testing	Test Report Number: 18-004767	13/09/2018	AS/NZS 3837:1998, "Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter"	Accreditation No. 1356
3	BRANZ	Report No.: DC 1869	22/2/2010	"Testing of NRG Building Systems Pty Ltd EPS Specimens"	ilac-MRA via. IANZ Accreditation No. 918
4	BRANZ	Report No.: DI 0031/01	22/4/2009	"Thermal Resistance of an Insulation Sample"	ilac-MRA via. IANZ Accreditation No. 37
5	Exova Warringtonfire	EWFA Report No.: 2581501.2	Test Date: 27/09/2017	"Full scale bushfire external wall test of a framed wall system in accordance with AS1530.8.1-2007"	Accreditation No. 3277 Site No. 3270
6	Exova Warringtonfire	EWFA Report No.: 26733-R6.1 (FAS220125)	Issue Date: 30/10/2023 Expiry date: 31/05/2027	"External framed wall system in accordance with AS1530.8.1-2007"	Accreditation No. 3277 Site No. 3270
7	Exova Warringtonfire	Certificate No.: 26733 SOA6.1	Issue Date: 02/11/2023 Expiry date: 31/05/2027	Summary of Assessment	Accreditation No. 3277 Site No. 3270
8	Structural Testing Services (STS)	Test ID #: STS-10-258-P	3/12/2010	"Screw Pullout Test Report"	Not applicable
9	SUMMERMORE Pty Ltd Ron Bell	-	3/11/2011	"Report on NRG Greenboard™ Evidence of Suitability"	Not applicable
10	SUMMERMORE Pty Ltd Ron Bell	-	16/3/2012	"Report on Impact Testing of NRG Board"	Not applicable
11	SUMMERMORE Pty Ltd Ron Bell	-	29/4/2012	"NRG Greenboard Cladding"	Not applicable
12	SUMMERMORE Pty Ltd Ron Bell	-	12/11/2012	"Report on Bending Testing of NRG Green Board Cladding"	Not applicable
13	SUMMERMORE Pty Ltd Ron Bell	17-12560	4/3/2017	"Report on NRG Greenboard™ Cladding Fixing Requirements"	Not applicable
14	NRG	-	Aug 2022	NRG Greenboard™ Specification 11th Edition (Aug 2022)	Not applicable

The Certificate Holder has chosen not to make the above identified evidence of compliance publicly available, due to the documents being considered commercial in confidence.